

Manual Supplement

Manual Title: 114,115, and 117 Users Supplement Issue: **3**
Part Number: 2538674, 2572573 Issue Date: 4/13
Print Date: July 2006 Page Count: 2
Revision/Date: 1, 2/07

This supplement contains information
necessary to ensure the accuracy of
the above manual.

Change #1


On page 2, under **Safety Information**:

Change: Do not use the Meter around explosive gas or vapor.

To: Do not use the Product around explosive gas, vapor, or in damp or wet environments.

Change #2, 63151, 63350

On page 3, add the following to the Symbols Table:

| | |
|---|--|
|  | Conforms to relevant South Korean EMC Standards |
| CAT II | Measurement Category II is applicable to test and measuring circuits connected directly to utilization points (socket outlets and similar points) of the low-voltage MAINS installation. |
| CAT III | Measurement Category III is applicable to test and measuring circuits connected to the distribution part of the building's low-voltage MAINS installation. |

| | |
|--------|--|
| CAT IV | Measurement Category IV is applicable to test and measuring circuits connected at the source of the building's low-voltage MAINS installation. |
|--------|--|

On pages 19 & 20, under ***General Specifications***, delete **Surge Protection, Safety Compliance and Certifications** and add:

SafetyIEC 61010-1: 600 V CAT III, Pollution Degree 2

Electromagnetic EnvironmentIEC 61326-1: Portable

Electromagnetic CompatibilityApplies to use in Korea only:

Class A Equipment (Industrial Broadcasting &
Communication Equipment) ^[1]

[1] This product meets requirements for industrial (Class A) electromagnetic wave equipment and the seller or user should take notice of it. This equipment is intended for use in business environments and is not to be used in homes.